

## Noise Monitoring Results - Clyde Junction Project WE02 July 2015

Noise Catchment Area	Monitoring Location	Date	Time (24hr) & Duration (mins)	Construction Activities	Standard or Out of Hours Works (Day/Evening/Night)	Weather Conditions	In Response to Complaint?	RBL (dBA) - from EIS	Noise Goal <sup>1</sup> (RBL+ 5dBA)	Recorded Noise Level LAeq (15 min) (dBA)	Recorded Noise Level LA5 (dBA)	Recorded Noise Level LA10 (dBA)	Recorded Noise Level L90 (dBA)	Person Carrying Out Noise Monitoring	Comments
NCA4	5 Seventh St, Granville	11/07/2015	21:30 - 21:45	Drainage Installation at Granville Station	OOHW Night	Heavy Rain	No	40	45	-	-	-	-	Maulik Bapodara	CJP Activities Inaudible, monitoring voided due to inclement weather
NCA5	Rawson Street, Auburn	12/07/2015	00:30 - 00:45	Drainage Installation at Clyde Station	OOHW Night	Heavy Rain	No	53	58	55	52	53	55	Maulik Bapodara	CJP Activities Inaudible, traffic on road and trains noise dominant
NCA6	Cnr of William St and Factory St	13/07/2015	22:15 - 22:30	Spoil handling, Jack hammering	OOHW Night	Cloudy	No	50	55	58	56	55	57	Maulik Bapodara	Cars - 73 dBA, Trains - 60 dBA, Idle - 50 dBA, Jackhammering activity inaudible
NCA7	Granville Hotel	14/07/2015	00:00 - 00:15	Drainage Installation at Granville Station	OOHW Night	Cloudy	No	50	55	55	56	51	57	Maulik Bapodara	CJP Activities Inaudible, traffic on road and freight trains noise dominant
NCA8	Railway Parade	15/07/2015	01:00 - 01:15	Spoil handling	OOHW Night	Cloudy	No	42	47	50	56	53	55	Maulik Bapodara	CJP Activities noticeable
NCA9	Enid Avenue	16/07/2015	23:20 - 23:35	No Works due to inclement weather	OOHW Night	Thunderstorm, lightening	No	56	61	-	-	-	-	Maulik Bapodara	CJP Activities Inaudible, monitoring voided due to inclement weather

**Note 1:** Noise goals are applicable to the noise contribution from Clyde Junction related construction activities only

**Note 2:** All CJP Construction Activities are inaudible at residential areas

