

**Noise Monitoring - Parramatta Turnback Project - WE02 - 9-10 July 2016**

Monitoring Location	Date	Time (24Hr) & Duration (minutes)	Construction Activities	Standard or Out-of-Hour Works (Day/Evening/Night)	Weather Conditions	In Response to Complaint?	RBL (dBA) - from EIA Checklist	Noise Goal (RBL + 5dBA)	Predicted Levels	Recorded Noise Level LAeq (15 min) (dBA)	Recorded Noise Level LAmx (dBA)	Recorded Noise Level LAmin (dBA)	Recorded Noise Level LA10 (dBA)	Recorded Noise Level L90 (dBA)	Compliance	Person Carrying Out Noise Monitoring	Comments
Marion St	9/07/2016	06:58 to 07:13	Harris Park Car Park Site compound, material loading and unloading, generator running	OOHW Day	Cloudy	No	48	53	57	57	61	56	59	49	Yes	Charissa Pillay	
Hunter St	9/07/2016	13:18 to 13:33	Excavations and tamping	OOHW Day	Cloudy	No	48	53	61	61	82	58	80	53	Yes	Charissa Pillay	