

Noise Monitoring - Parramatta Turnback Project - WE40 9-10 April 2016

Monitoring Location	Date	Time (24Hr & Duration (minutes)	Construction Activities	Standard or Out-of-Hour Works (Day/Evening/Night)	Weather Conditions	In Response to Complaint?	RBL (dBA) - from EIA Checklist	Noise Goal (RBL + 5dBA)	Prediceted Levels	Recorded Noise Level LAeq (15 min) (dBA)	Recorded Noise Level LAmax (dBA)	Recorded Noise Level LAmin (dBA)	Recorded Noise Level LA10 (dBA)	Recorded Noise Level L90 (dBA)	Compliance	Person Carrying Out Noise Monitoring	Comments
45 (East end of) Hunter St, Parramatta	9/04/2016	18:17 to 18:32	Excavator	OOHW Evening	Fine	No	48	53	65	63	83	50	64	53	Yes	Risha Imtiaz	Traffic noise from Hunter St and Marsden St Car = 70 dBA Train = 61 dBA Noisy Car = 82 dBA
45 Hunter St, Parramatta	9/04/2016	23:21 to 23:36	Plant movements	OOHW Night	Fine	No	48	53	58	56	79	38	59	49	Yes	Risha Imtiaz	Traffic noise from Hunter St and Marsden St Car = 71 dBA Train = 60 dBA Noisy Car = 78 dBA