

Sediment Basin Water Monitoring - June 2016



Basin Location	Basin name	Date of treatment	Date of discharge	Volume discharged (m3)	EPL water quality parameter (Job No. F1290)		
					Visible oil & grease	pH	TSS
					Nil	6.5 – 8.5	Limit ≤ 50 mg/L
Wave 1	Greenhill cutting	N/A	23-24 June 2016	1097	Nil	6.96	24
	Tyndale Cutting	N/A	23-24 June 2016	450	Nil	7.5	15